



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Slauson Middle School							
Date of Sampling: 2/29/2020							
Sampler: Carly Doulos							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Slauson-01	Cafeteria, Hydration Station, Bottle Fill	BT	8:47 AM	5	ND ³	N	First Draw, Filtered.
Slauson-02	Hallway, Outside of Lower Gym, Hydration Station, Bottle Fill	BT	7:36 AM	5	ND	N	First Draw, Filtered.
Slauson-03	Hallway, Outside of Lower Gym, Hydration Station, Water Cooler	BT	7:38 AM	5	ND	N	First Draw, Filtered.
Slauson-04	Hallway, Outside of Room 146, Hydration Station, Bottle Fill	BT	8:05 AM	5	ND	N	First Draw, Filtered.
Slauson-05	Girl's Locker Room, Bubbler	B	7:42 AM	5	ND	N	First Draw, Filtered.
Slauson-06	Boy's Locker Room, Bubbler	B	7:45 AM	5	ND	N	First Draw, Filtered.
Slauson-07	Hallway, Outside of Room 146, Hydration Station, Water Cooler	BT	8:07 AM	5	ND	N	First Draw, Filtered.
Slauson-08	Room 138, Special Education, Single Sink, Left Faucet	F	8:15 AM	5	ND	Y	First Draw, Filtered.
Slauson-09	Room 138, Special Education, Single Sink, Right Faucet	F	8:17 AM	5	ND	Y	First Draw, Filtered.
Slauson-10	Room 138, 2-Compartment, Kitchen Faucet	KF	8:20 AM	5	1	Y	First Draw, Filtered.
Slauson-11	Hallway, Outside of Room 138, Hydration Station, Water Cooler	BT	8:21 AM	5	ND	N	First Draw, Filtered.
Slauson-12	Men's Pool Locker Room, Bubbler	B	8:33 AM	5	ND	N	First Draw, Filtered.
Slauson-13	Pool Deck, Hydration Station, Water Cooler	BT	8:36 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Slauson Middle School							
Date of Sampling: 2/29/2020							
Sampler: Carly Doulos							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Slauson-14	Women's Pool Locker Room, Water Cooler	WC	8:26 AM	5	ND	N	First Draw, Filtered.
Slauson-15	Hallway, Outside Room 224, Hydration Station, Water Cooler	BT	9:16 AM	5	ND	N	First Draw, Filtered.
Slauson-16	Hallway, Outside Room 204, Single Water Cooler	WC	8:55 AM	5	ND	N	First Draw, Filtered.
Slauson-17	Library Lounge, Kitchen Faucet	KF	9:33 AM	5	ND	Y	First Draw, Filtered.
Slauson-18	Hallway, Outside Library Lounge, Left Hydration Station, Water Cooler	BT	9:24 AM	5	ND	N	First Draw, Filtered.
Slauson-19	Hallway, Outside Library Lounge, Right Hydration Station, Bottle Fill	BT	9:28 AM	5	ND	N	First Draw, Filtered.
Slauson-20	Hallway, Outside Library Lounge, Right Hydration Station, Water Cooler	BT	9:29 AM	5	ND	N	First Draw, Filtered.
Slauson-21	Main Office, Kitchen Faucet	KF	9:37 AM	5	ND	Y	First Draw, Filtered.
Slauson-22	Gym, Hydration Station, Bottle Fill	BT	7:56 AM	5	ND	N	First Draw, Filtered.
Slauson-23	Gym, Hydration Station, Water Cooler	BT	7:58 AM	5	ND	N	First Draw, Filtered.
Slauson-24	Auditorium Lobby, Hydration Station, Bottle Fill	BT	8:58 AM	5	ND	N	First Draw, Filtered.
Slauson-25	Auditorium Lobby, Hydration Station, Water Cooler	BT	8:59 AM	5	ND	N	First Draw, Filtered.
Slauson-26	Auditorium Lobby, Single Water Cooler	WC	9:05 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Slauson Middle School							
Date of Sampling: 2/29/2020							
Sampler: Carly Doulos							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Slauson-27	Hallway, Outside Room 203, Single Water Cooler	WC	9:07 AM	5	ND	N	First Draw, Filtered.
Slauson-28	Hallway, Outside Room 324, Hydration Station, Water Cooler	BT	10:31 AM	5	ND	N	First Draw, Filtered.
Slauson-29	Room 346, Faucet	F	9:43 AM	5	ND	Y	First Draw, Filtered.
Slauson-30	Hallway, Outside Room 348, Hydration Station, Water Cooler	BT	9:48 AM	5	ND	N	First Draw, Filtered.
Slauson-31	Computer Room, Rooms 300 & 300A, Faucet	F	10:15 AM	5	5	Y	First Draw, Filtered.
Slauson-32	Room 211, Faucet	F	9:13 AM	5	1	Y	First Draw, Filtered.
Slauson-33	Hallway, Outside of Room 138, Hydration Station, Bottle Fill	BT	8:22 AM	5	ND	N	First Draw, Filtered.
Slauson-34	Hallway, Outside Room 303, Hydration Station, Water Cooler	BT	10:18 AM	5	ND	N	First Draw, Filtered.
Slauson-35	Kitchen, 3-Compartment, Add On Single Faucet, Far Right	KF	8:44 AM	5	ND	Y	First Draw, Filtered.
Slauson-36	Hallway, Outside of Room 146, Right Single Water Cooler	WC	8:09 AM	5	ND	N	First Draw, Filtered.
Slauson-37	Cafeteria, Hydration Station, Water Cooler	BT	8:49 AM	5	ND	N	First Draw, Filtered.
Slauson-38	Room 203, Faucet	F	9:10 AM	5	1	Y	First Draw, Filtered.
Slauson-39	Clinic, Faucet	F	9:40 AM	5	3	Y	First Draw, Filtered.
Slauson-40	Room 321, Work Room, Faucet	F	10:05 AM	5	ND	Y	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Slauson Middle School							
Date of Sampling: 2/29/2020							
Sampler: Carly Doulos							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Slauson-41	OPEN NUMBER			5			
Slauson-42	Lower Auxiliary Gym, Water Cooler	WC	7:49 AM	5	ND	N	First Draw, Filtered.
Slauson-43	Hallway, Outside Library Lounge, Left Hydration Station, Bottle Fill	BT	9:25 AM	5	ND	N	First Draw, Filtered.
Slauson-44	Hallway, Outside Room 224, Hydration Station, Bottle Fill	BT	9:18 AM	5	ND	N	First Draw, Filtered.
Slauson-45	Hallway, Outside Room 324, Hydration Station, Bottle Fill	BT	10:29 AM	5	ND	N	First Draw, Filtered.
Slauson-46	Hallway, Outside Room 348, Hydration Station, Bottle Fill	BT	9:49 AM	5	ND	N	First Draw, Filtered.
Slauson-47	Hallway, Outside Room 348, Single Water Cooler	WC	9:50 AM	5	ND	N	First Draw, Filtered.
Slauson-48	Hallway, Outside Room 303, Hydration Station, Bottle Fill	BT	10:20 AM	5	ND	N	First Draw, Filtered.
Slauson-49	Pool Deck, Hydration Station, Bottle Fill	BT		5			Sampled on 3/10/2020

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested



Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030

Slauson Middle School							
Date of Sampling: 3/10/2020							
Sampler: Alex Reiber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Slauson-49	Pool Deck, Hydration Station, Bottle Fill	BT	7:15 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested