



Ann Arbor Public Schools  
Drinking Water Analysis  
Project Number: AE230030

Huron High School									
Date of Sampling: January 4, 2023									
Sampler: Sabrina Fouche									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Huron-02	Southeast Wing, Floor 1, Across from Main Office, Refrigerated, Glass Filler	G	11:58 AM	5	ND <sup>3</sup>	N	Y	Unknown	Initial First Draw, Filtered.
Huron-07	Southeast Wing, Floor 1, Media Center, Left Hydration Station, Bottle Fill	HS	11:45 AM	5	ND	Y	Y	Green	Initial First Draw, Filtered.
Huron-10	Northwest Wing, Floor 1, Outside Room 2100, Refrigerated, Glass Filler	G	10:36 AM	5	ND	N	Y	Unknown	Initial First Draw, Filtered.
Huron-13	Floor 1, Southeast Wing, Outside Room 7109, Refrigerated, Glass Filler	G	11:54 PM	5	ND	N	Y	Unknown	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools  
Drinking Water Analysis  
Project Number: AE230030

Huron High School									
Date of Sampling: January 4, 2023									
Sampler: Sabrina Fouche									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Huron-14	Northwest Wing, Pool, Diving Boards, Left Stainless Steel, Glass Filler	G	10:30 AM	5	ND	N	Y	Unknown	Initial First Draw, Filtered.
Huron-19	Northwest Wing, Pool, West Wall, Hydration Station, Bottle Fill	HS	10:28 AM	5	ND	Y	Y	Green	Initial First Draw, Filtered.
Huron-35	Southeast Wing, Floor 1, Across from Room 7150, Refrigerated, Glass Filler	G	11:50 AM	5	ND	N	Y	Unknown	Initial First Draw, Filtered.
Huron-40	"Green House", 2-Compartment Sink, , Kitchen Faucet	KF	11:01 AM	5	ND	Y	Y	7/22/22	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools  
Drinking Water Analysis  
Project Number: AE230030

Huron High School									
Date of Sampling: January 4, 2023									
Sampler: Sabrina Fouche									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Huron-43	Dome Gym, Steel, Glass Filler	G	10:56 AM	5	ND	N	Y	Unknown	Initial First Draw, Filtered.
Huron-44	Dome Gym, North Porcelain, Glass Filler	G	10:50 AM	5	ND	N	Y	8/2/22	Initial First Draw, Filtered.
Huron-51	Southeast Wing, Floor 2, Across from Room 6212, Single Bottle Fill	BT	11:31 AM	5	ND	N	Y	Unknown	Initial First Draw, Filtered.
Huron-52	Room 6216, 2-Compartment Sink, Combination Sink, Glass Filler	C	11:26 PM	5	ND	N	Y	Unknown	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools  
Drinking Water Analysis  
Project Number: AE230030

Huron High School									
Date of Sampling: January 4, 2023									
Sampler: Sabrina Fouche									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Huron-55	Life Skills Room 6219, South Wall, 2-Compartment Sink, Combination Sink, Glass Filler	C	11:17 AM	5	ND	N	Y	Unknown	Initial First Draw, Filtered.
Huron-58	Life Skills Room 6219, East Wall, Left, 2-Comp Sink, Combination Sink, Glass Filler	C	11:19 AM	5	ND	N	Y	Unknown	Initial First Draw, Filtered.
Huron-61	Life Skills Room 6219, West Wall, Middle, 2-Comp Sink, Combination Sink, Glass Filler	C	11:15 AM	5	ND	N	Y	7/28/22	Initial First Draw, Filtered.
Huron-64	Hallway, Southeast Wing, Floor 2, Across from Room 5200, Refrigerated, Glass Filler	G	11:08 AM	5	ND	N	Y	Unknown	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools  
Drinking Water Analysis  
Project Number: AE230030

Huron High School									
Date of Sampling: January 4, 2023									
Sampler: Sabrina Fouche									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Huron-66	Hallway, Floor 3, Outside Room 4311, Hydration Station, Bottle Fill	HS	11:38 AM	5	ND	Y	Y	Green	Initial First Draw, Filtered.
Huron-73	Northwest Wing, Floor 1, Outside Room 1110, Hydration Station, Bottle Fill	HS	10:21 AM	5	ND	Y	Y	Green	Initial First Draw, Filtered.
Huron-75	Cafeteria, West, Outside Kitchen, Hydration Station, Bottle Fill	HS	10:17 AM	5	ND	Y	Y	Green	Initial First Draw, Filtered.
Huron-78	Northwest Wing, Floor 2, Across from Room 2201, Hydration Station, Bottle Fill	HS	11:05 AM	5	ND	Y	Y	Green	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools  
Drinking Water Analysis  
Project Number: AE230030

Huron High School									
Date of Sampling: January 4, 2023									
Sampler: Sabrina Fouche									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Huron-79	Hallway, Southeast Wing, Floor 2, Outside Room 6203, Hydration Station, Bottle Fill	HS	11:22 AM	5	ND	Y	Y	Green	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L