



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE240030

Site: Tappan Middle School									
Sampling Type: Initial First Draw Sampling (IFD)									
Date of Sampling: February 3, 2024									
Sampler: Zac Fortin									
Sample #	Location	Fixture Type	Time Collected	District Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date	Notes
Tappan-13	Nurse's Clinic, Combination Sink, Glass Filler	Combination Sink	2:53 PM	5	ND	Y	Y	6/29/2023	
Tappan-18	Pool, West Wall Near Girls Locker Room, Glass Filler	Glass Filler	3:15 PM	5	ND	N	N/A	N/A	
Tappan-21	Boy's Locker Room, Porcelain, Glass Filler	Glass Filler	3:09 PM	5	ND	Y	Y	6/29/2023	
Tappan-26	Room 106, Combination Sink, Glass Filler	Combination Sink	3:02 PM	5	ND	Y	Y	6/30/2023	
Tappan-37	Third Floor, Teacher's Lounge, Combination Sink, Glass Filler	Combination Sink	2:34 PM	5	ND	Y	Y	6/30/2023	
Tappan-51	Hallway, By Room 208, Across Stairwell, Hydration Station, Bottle Fill	Bottle Fill	2:42 PM	5	ND	Y	Y	N/A	
Tappan-54	Hallway, Outside Room 337, Hydration Station, Bottle Fill	Bottle Fill	2:29 PM	5	ND	Y	Y	N/A	

*ND = Non-Detected at Reported Detection Limit of 1 ug/L