



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE240030

Site: Dicken Elementary School									
Sampling Type: Initial First Draw Sampling (IFD)									
Date of Sampling: February 17, 2024									
Sampler: Teagan Evans									
Sample #	Location	Fixture Type	Time Collected	District Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date	Notes
Dicken-32	Hallway, Outside Room 123, Hydration Station, Bottle Fill	Hydration Station	11:32 AM	5	ND	Y	N	N/A	
Dicken-59	Hallway, Outside Room 120, Hydration Station, Bottle Fill	Hydration Station	11:39 AM	5	ND	Y	N	N/A	
Dicken-06	Room 114, Left Combination Sink, Glass Filler	Combination Sink	12:10 PM	5	ND	N	N	N/A	
Dicken-14	Room 120, Combination Sink, Glass Filler	Combination Sink	11:44 AM	5	ND	N	N	N/A	
Dicken-19	Room 102, Combination Sink, Glass Filler	Combination Sink	11:50 AM	5	ND	N	N	N/A	
Dicken-22	Room 108, Combination Sink, Glass Filler	Combination Sink	11:56 AM	5	ND	N	N	N/A	
Dicken-24	Room 112, Combination Sink, Glass Filler	Combination Sink	12:02 PM	5	ND	N	N	N/A	
Dicken-26	Room 113, Right Combination Sink, Glass Filler	Combination Sink	12:06 PM	5	ND	N	N	N/A	
Dicken-28	Room 109, Combination Sink, Glass Filler	Combination Sink	12:00 PM	5	ND	N	N	N/A	
Dicken-30	Room 105, Combination Sink, Glass Filler	Combination Sink	11:53 AM	5	ND	N	N	N/A	

*ND = Non-Detected at Reported Detection Limit of 1 ug/L