



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE240030

Site: Lawton Elementary School									
Sampling Type: Initial First Draw Sampling (IFD)									
Date of Sampling: February 16, 2024									
Sampler: Dean Johnson									
Sample #	Location	Fixture Type	Time Collected	District Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date	Notes
Lawton-01	Room 310, Combination Sink, Glass Filler	Combination Sink	11:12 AM	5	ND	Y	Y	7/11/2023	
Lawton-02	Receiving Room, Glass Filler	Glass Filler	11:43 AM	5	ND	Y	Y	7/10/2023	
Lawton-03	Room 316, Combination Sink, Glass Filler	Combination Sink	11:08 AM	5	ND	Y	Y	7/11/2023	
Lawton-04	Gym, Wall Glass Filler	Glass Filler	11:53 AM	5	ND	Y	N/A	N/A	
Lawton-05	Room 210, Combination Sink, Glass Filler	Combination Sink	11:35 AM	5	ND	Y	Y	7/11/2023	
Lawton-06	Cafeteria/Auditorium, Right Single Bottle Fill	Single Bottle Fill	12:08 PM	5	ND	Y	N/A	N/A	
Lawton-17	Room 305, Combination Sink, Glass Filler	Combination Sink	11:24 AM	5	ND	Y	Y	7/11/2023	

*ND = Non-Detected at Reported Detection Limit of 1 ug/L



**Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE240030**

Site: Lawton Elementary School									
Sampling Type: Initial First Draw Sampling (IFD)									
Date of Sampling: February 16, 2024									
Sampler: Dean Johnson									
Sample #	Location	Fixture Type	Time Collected	District Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date	Notes
Lawton-19	Room 303, Combination Sink, Glass Filler	Combination Sink	11:33 AM	5	ND	Y	Y	7/11/2023	
Lawton-21	Room 301, Combination Sink, Glass Filler	Combination Sink	11:29 AM	5	ND	Y	Y	7/11/2023	
Lawton-31	Room 201, Combination Sink, Glass Filler	Combination Sink	12:19 PM	5	ND	Y	Y	7/10/2023	
Lawton-35	Hallway Outside Room 101, Hydration Station, Bottle Fill	Hydration Station	12:21 PM	5	ND	Y	N/A	N/A	
Lawton-41	Room 108, Combination Sink, Glass Filler	Combination Sink	11:00 AM	5	ND	Y	Y	7/11/2023	
Lawton-43	Room 106, Combination Sink, Glass Filler	Combination Sink	10:46 AM	5	ND	Y	Y	7/11/2023	
Lawton-04-R	Gym, Wall, Right Glass Filler	Glass Filler	10:53 AM	5	ND	Y	N/A	N/A	

*ND = Non-Detected at Reported Detection Limit of 1 ug/L