



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

Thurston Elementary School							
Date of Sampling: 1/25/2020							
Sampler: Steven Ripley							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Thurston-01	Hallway, in Front of Custodian Lounge, Hydration Station, Water Cooler	BT	11:35 AM	5	1	N	First Draw, Filtered.
Thurston-02	OPEN NUMBER			5			
Thurston-03	Hallway, Left of Office, Left Single Water Cooler	WC	10:25 AM	5	2	N	First Draw, Filtered.
Thurston-04	Hallway, to Left of Office, Hydration Station, Water Cooler	BT	10:20 AM	5	2	N	First Draw, Filtered.
Thurston-05	Hallway, Left of Multipurpose Room D103, Hydration Station, Water Cooler	BT	11:10 AM	5	ND <sup>3</sup>	N	First Draw, Filtered.
Thurston-06	Hallway, Left of Multipurpose Room D103, Right Single Water Cooler			5			Location Not Currently Functional
Thurston-07	Room C2, Combination Sink, Bubbler	C	10:45 AM	5	ND	N	First Draw, Filtered.
Thurston-08	Room 3, Combination Sink, Bubbler	C	10:55 AM	5	ND	N	First Draw, Filtered.
Thurston-09	Room 4, Combination Sink, Bubbler	C	11:00 AM	5	ND	N	First Draw, Filtered.
Thurston-10	Room 8, Combination Sink, Bubbler	C	12:50 PM	5	ND	N	First Draw, Filtered.
Thurston-11	Room 9, Combination Sink, Bubbler	C	12:55 PM	5	1	N	First Draw, Filtered.
Thurston-12	Room 10, Combination Sink, Bubbler	C	1:00 PM	5	ND	N	First Draw, Filtered.
Thurston-13	Room 28, Combination Sink, Bubbler	C	12:35 PM	5	ND	N	First Draw, Filtered.
Thurston-14	Room 28, Combination Sink, Faucet	C	12:35 PM	5	1	Y	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
4) NT = Not Tested



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

Thurston Elementary School							
Date of Sampling: 1/25/2020							
Sampler: Steven Ripley							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Thurston-15	Room 26, Combination Sink, Bubbler	C	12:25 PM	5	ND	N	First Draw, Filtered.
Thurston-16	Room 26, Combination Sink, Faucet	C	12:25 PM	5	1	Y	First Draw, Filtered.
Thurston-17	Room 24, Combination Sink, Bubbler	C	12:15 PM	5	ND	N	First Draw, Filtered.
Thurston-18	Room 24, Combination Sink, Faucet	C	12:15 PM	5	1	Y	First Draw, Filtered.
Thurston-19	Room 22, Combination Sink, Bubbler	C	12:04 PM	5	ND	N	First Draw, Filtered.
Thurston-20	Room 22, Combination Sink, Faucet	C	12:04 PM	5	2	Y	First Draw, Filtered.
Thurston-21	Room 27, Combination Sink, Bubbler	C	12:30 PM	5	ND	N	First Draw, Filtered.
Thurston-22	Room 27, Combination Sink, Faucet	C	12:30 PM	5	2	Y	First Draw, Filtered.
Thurston-23	Room 25, Combination Sink, Bubbler	C	12:20 PM	5	ND	N	First Draw, Filtered.
Thurston-24	Room 25, Combination Sink, Faucet	C	12:20 PM	5	1	Y	First Draw, Filtered.
Thurston-25	Room 23, Combination Sink, Bubbler	C	12:12 PM	5	ND	N	First Draw, Filtered.
Thurston-26	Room 23, Combination Sink, Faucet	C	12:12 PM	5	1	Y	First Draw, Filtered.
Thurston-27	Room 21, Combination Sink, Bubbler	C	11:58 AM	5	ND	N	First Draw, Filtered.
Thurston-28	Room 21, Combination Sink, Faucet	C	11:58 AM	5	1	Y	First Draw, Filtered.
Thurston-29	Hallway, Outside Room 22, Hydration Station, Water Cooler	BT	12:08 PM	5	ND	N	First Draw, Filtered.
Thurston-30	Room 7, Combination Sink, Bubbler	C	12:45 PM	5	ND	N	First Draw, Filtered.
Thurston-31	Room 7, Combination Sink, Faucet	C	12:45 PM	5	1	Y	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
4) NT = Not Tested



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

Thurston Elementary School							
Date of Sampling: 1/25/2020							
Sampler: Steven Ripley							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Thurston-32	Room 8, Combination Sink, Faucet	C	12:50 PM	5	1	Y	First Draw, Filtered.
Thurston-33	Room K11, Combination Sink, Bubbler	C	1:05 PM	5	3	N	First Draw, Filtered.
Thurston-34	Room K11, Combination Sink, Faucet	C	1:05 PM	5	7	Y	First Draw, Filtered.
Thurston-35	Room A101, Combination Sink, Bubbler	C	1:25 PM	5	ND	N	First Draw, Filtered.
Thurston-36	Room A101, Combination Sink, Faucet	C	1:25 PM	5	ND	Y	First Draw, Filtered.
Thurston-37	Room A106, Combination Sink, Bubbler	C	1:20 PM	5	ND	N	First Draw, Filtered.
Thurston-38	Room A106, Combination Sink, Faucet	C	1:20 PM	5	ND	Y	First Draw, Filtered.
Thurston-39	Room K12, Combination Sink, Bubbler	C	1:10 PM	5	ND	N	First Draw, Filtered.
Thurston-40	Room K12, Combination Sink, Faucet	C	1:10 PM	5	ND	Y	First Draw, Filtered.
Thurston-41	Room 9, Combination Sink, Faucet	C	12:55 PM	5	1	Y	First Draw, Filtered.
Thurston-42	Room 10, Combination Sink, Faucet	C	1:00 PM	5	ND	Y	First Draw, Filtered.
Thurston-43	Main Office Kitchenette, Faucet	F	10:15 AM	5	2	Y	First Draw, Filtered.
Thurston-44	Room C1, Combination Sink, Bubbler	C	10:25 AM	5	ND	N	First Draw, Filtered.
Thurston-45	Room C1, Combination Sink, Faucet	C	10:25 AM	5	4	Y	First Draw, Filtered.
Thurston-46	Room C2, Combination Sink, Faucet	C	10:45 AM	5	2	Y	First Draw, Filtered.
Thurston-47	Room 3, Combination Sink, Faucet	C	10:55 AM	5	1	Y	First Draw, Filtered.
Thurston-48	Room 4, Combination Sink, Faucet	C	11:00 AM	5	1	Y	First Draw, Filtered.
Thurston-49	Room 5, Combination Sink, Bubbler	C	10:50 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
4) NT = Not Tested



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

Thurston Elementary School							
Date of Sampling: 1/25/2020							
Sampler: Steven Ripley							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Thurston-50	Room 5, Combination Sink, Faucet	C	10:50 AM	5	1	Y	First Draw, Filtered.
Thurston-51	Room 6, Combination Sink, Bubbler	C	10:30 AM	5	ND	N	First Draw, Filtered.
Thurston-52	Room 6, Combination Sink, Faucet	C	10:30 AM	5	1	Y	First Draw, Filtered.
Thurston-53	Hallway, Left of Office, Hydration Station, Bottle Fill	BT	10:20 AM	5	2	N	First Draw, Filtered.
Thurston-54	Hallway, Left of Multipurpose Room D103, Hydration Station, Bottle Fill	BT	11:05 AM	5	ND	N	First Draw, Filtered.
Thurston-55	Kitchen, Three-Compartment Sink, Single Add on Faucet, Far Left	KF	11:20 AM	5	ND	Y	First Draw, Filtered.
Thurston-56	OPEN NUMBER			5			
Thurston-57	Portable, Left Single Water Cooler	WC	11:40 AM	5	ND	N	First Draw, Filtered.
Thurston-58	Portable, Hydration Station, Water Cooler	BT	11:42 AM	5	ND	N	First Draw, Filtered.
Thurston-59	Portable, Hydration Station, Bottle Fill	BT	11:42 AM	5	1	N	First Draw, Filtered.
Thurston-60	Hallway, Outside Room C-2, Hydration Station, Water Cooler	BT	10:35 AM	5	ND	N	First Draw, Filtered.
Thurston-61	Hallway, Outside Room C-2, Hydration Station, Bottle Fill	BT	10:35 AM	5	ND	N	First Draw, Filtered.
Thurston-62	Hallway, in Front of Custodian Lounge, Hydration Station, Water Cooler	BT	11:35 AM	5	ND	N	First Draw, Filtered.
Thurston-63	Hallway, Outside Room 22, Hydration Station, Bottle Fill	BT	12:08 PM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

Thurston Elementary School							
Date of Sampling: 1/25/2020							
Sampler: Steven Ripley							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Thurston-64	Hallway, Outside Room K12, Hydration Station, Water Cooler	BT	1:15 PM	5	ND	N	First Draw, Filtered.
Thurston-65	Hallway, Outside Room K12, Hydration Station, Bottle Fill	BT	1:15 PM	5	ND	N	First Draw, Filtered.

Thurston Elementary School							
Date of Sampling: 2/8/2020							
Sampler: Amanda Peterson							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Thurston-06	Hallway, Left of Multipurpose Room D103, Right Single Water Cooler	WC	3:36 PM	5	ND	N	First Draw, Filtered. Location Previously Not Functional.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
4) NT = Not Tested



Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030

Thurston Elementary School							
Date of Sampling: 2/8/2020							
Sampler: Amanda Peterson							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Thurston-34A	Room KI1, Combination Sink, Faucet	C	3:50 PM	5	4	Y	Repeat First Draw, Filtered. Elevated Lead Attributed to Sediment in Aerator. Aerator Placed on Cleaning Schedule.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
4) NT = Not Tested