



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

Bach Elementary School							
Date of Sampling: 12/14/2019							
Sampler: Steven Ripley							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Bach-01	Room 202, Combination Sink, Bubbler	C	11:05 AM	5	ND <sup>3</sup>	N	First Draw, Filtered
Bach-02	Staff Lounge, Kitchen Faucet	KF	10:50 AM	5	ND	Y	First Draw, Filtered
Bach-03	Room A-24, Combination Sink, Bubbler	C	10:15 AM	5	ND	N	First Draw, Filtered
Bach-04	Room A-25, Combination Sink, Bubbler	C	10:20 AM	5	ND	Y	First Draw, Filtered
Bach-05	Room A-26, Combination Sink, Bubbler	C	10:25 AM	5	ND	N	First Draw, Filtered
Bach-06	Room A-29, Combination Sink, Bubbler	C	10:45 AM	5	ND	N	First Draw, Filtered
Bach-07	Room 19, Combination Sink, Bubbler	C	9:40 AM	5	ND	N	First Draw, Filtered
Bach-08	Room 20, Combination Sink, Bubbler	C	9:48 AM	5	ND	N	First Draw, Filtered
Bach-09	Room 18, Combination Sink, Bubbler	C	9:36 AM	5	ND	N	First Draw, Filtered
Bach-10	Room 16, Combination Sink, Bubbler	C	9:30 AM	5	ND	N	First Draw, Filtered
Bach-11	Hallway Outside Room 104, Hydration Station, Water Cooler	BT	11:15 AM	5	ND	N	First Draw, Filtered
Bach-12	Hallway Outside Room 306, Hydration Station, Water Cooler	BT	11:10 AM	5	ND	N	First Draw, Filtered
Bach-13	Room 202, Combination Sink, Faucet	C	11:05 AM	5	ND	Y	First Draw, Filtered
Bach-14	Room A-24, Combination Sink, Faucet	C	10:15 AM	5	ND	Y	First Draw, Filtered

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

Bach Elementary School							
Date of Sampling: 12/14/2019							
Sampler: Steven Ripley							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Bach-15	Room A-26, Combination Sink, Faucet	C	10:25 AM	5	ND	Y	First Draw, Filtered
Bach-16	Room A-25, Combination Sink, Faucet	C	10:20 AM	5	2	N	First Draw, Filtered
Bach-17	Room 19, Combination Sink, Faucet	C	9:40 AM	5	ND	Y	First Draw, Filtered
Bach-18	Room A-29, Combination Sink, Faucet	C	10:45 AM	5	ND	Y	First Draw, Filtered
Bach-19	Room 18, Combination Sink, Faucet	C	9:36 AM	5	ND	Y	First Draw, Filtered
Bach-20	Room 16, Combination Sink, Faucet	C	9:30 AM	5	ND	Y	First Draw, Filtered
Bach-21	OPEN NUMBER						
Bach-23	Room 21, Combination Sink, Bubbler	C	9:55 AM	5	ND	N	First Draw, Filtered
Bach-24	Room 23, Combination Sink, Bubbler	C	9:45 AM	5	ND	N	First Draw, Filtered
Bach-25	Room 23, Combination Sink, Faucet	C	9:45 AM	5	ND	Y	First Draw, Filtered
Bach-26	Room 22, Combination Sink, Bubbler	C	9:52 AM	5	ND	N	First Draw, Filtered
Bach-27	Room 22, Combination Sink, Faucet	C	9:52 AM	5	ND	Y	First Draw, Filtered
Bach-28	Room A-27, Combination Sink, Bubbler	C	10:30 AM	5	ND	N	First Draw, Filtered
Bach-29	Room A-27, Combination Sink, Faucet	C	10:30 AM	5	ND	Y	First Draw, Filtered

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

Bach Elementary School							
Date of Sampling: 12/14/2019							
Sampler: Steven Ripley							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Bach-30	Room 20, Combination Sink, Faucet	C	9:48 AM	5	ND	N	First Draw, Filtered
Bach-31	Room 31, Clinic Single Faucet	F	10:55 AM	5	ND	Y	First Draw, Filtered
Bach-32	Auditorium, Single Faucet	F	10:10 AM	5	ND	Y	First Draw, Filtered
Bach-33	Auditorium, Hydration Station, Bottle Fill	BT	10:05 AM	5	ND	Y	First Draw, Filtered
Bach-34	In Hallway, Outside Media Center, Hydration Station, Bottle Fill	BT	11:00 AM	5	ND	Y	First Draw, Filtered
Bach-35	Room A-28, Combination Sink, Bubbler	C	10:40 AM	5	ND	N	First Draw, Filtered
Bach-36	Room A-28, Combination Sink, Faucet	C	10:40 AM	5	ND	N	First Draw, Filtered
Bach-37	Room C-104, Single Faucet	F	11:20 AM	5	ND	Y	First Draw, Filtered. Corrosion Noted on Aerator.
Bach-38	Room 21, Combination Sink, Faucet	C	9:55 AM	5	ND	N	First Draw, Filtered
Bach-39	In Hallway, Outside Media Center, Hydration Station, Water Cooler	BT	11:00 AM	5	ND	N	First Draw, Filtered
Bach-40	Auditorium, Hydration Station, Water Cooler	BT	10:05 AM	5	ND	N	First Draw, Filtered
Bach-41	Hallway, Outside Room 18, Hydration Station, Water Cooler	BT	9:32 AM	5	ND	N	First Draw, Filtered
Bach-42	Hallway, Outside Room 18, Hydration Station, Bottle Fill	BT	9:32 AM	5	ND	N	First Draw, Filtered

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee  
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
4) NT = Not Tested



Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030

Bach Elementary School							
Date of Sampling: 12/14/2019							
Sampler: Steven Ripley							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Bach-43	Hallway, Outside Room A-28, Hydration Station, Water Cooler	BT	10:35 AM	5	ND	N	First Draw, Filtered
Bach-44	Hallway, Outside Room A-28, Hydration Station, Bottle Fill	BT	10:35 AM	5	ND	N	First Draw, Filtered
Bach-45	Hallway Outside Room 104, Hydration Station, Bottle Fill	BT	11:15 AM	5	ND	N	First Draw, Filtered
Bach-46	Hallway Outside Room 306, Hydration Station, Bottle Fill	BT	11:10 AM	5	ND	N	First Draw, Filtered
Bach-47	Exterior of Building, Outside Exit Door at Room A-24, Bubbler						Location Turned off For Winter, to be Sampled at a Later Date.

Bach Elementary School							
Date of Sampling: 12/17/2019							
Sampler: Jenna Sendra							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Bach-22	Kitchen, 3-Compartment Sink, Far Left Faucet	KF	6:36	5	ND	Y	First Draw, Filtered

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
4) NT = Not Tested