



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE230030

Community High School									
Date of Sampling: January 3, 2023									
Sampler: Sabrina Fouche									
Sample #	Location	Type ¹	Time Collected	District Lead Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Community-10	Hallway, Outside Room 303, Hydration Station, Bottle Fill	HS	1:48 PM	5	ND ³	Y	Y	Unknown	Initial First Draw, Filtered.
Community-17	Hallway, Across from Room 111, Hydration Station, Bottle Fill	HS	1:44 PM	5	ND	Y	Y	Green	Initial First Draw, Filtered.
Community-20	Kitchen, Single Prep Sink	KF	1:35 PM	5	ND	Y	Y	7/27/22	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L