



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Dicken Elementary School							
Date of Sampling: 12/14/2019							
Sampler: Steven Ripley							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Dicken-01	Hallway, Adjacent from Room 123, Single Sink, Faucet	F	12:50 PM	5	2	Y	First Draw, Filtered.
Dicken-02	Main Office Nurse's Single Sink, Faucet	F	12:45 PM	5	ND ³	Y	First Draw, Filtered.
Dicken-03	Room 104, Combination Sink, Faucet	C	2:40 PM	5	4	Y	First Draw, Filtered.
Dicken-04	Room 112, Combination Sink, Faucet	C	3:50 PM	5	ND	Y	First Draw, Filtered.
Dicken-05	Room 114, Left Combination Sink, Faucet	C	4:10 PM	5	8	Y	First Draw, Filtered.
Dicken-06	Room 114, Left Combination Sink, Bubbler	C	4:10 PM	5	ND	N	First Draw, Filtered.
Dicken-07	Room 114, Right Combination Sink, Bubbler	C	4:15 PM	5	ND	N	First Draw, Filtered.
Dicken-08	Room 113, Left Combination Sink, Faucet	C	3:55 PM	5	4	Y	First Draw, Filtered.
Dicken-09	Room 113, Left Combination Sink, Bubbler	C	3:55 PM	5	ND	N	First Draw, Filtered.
Dicken-10	Room 113, Right Combination Sink, Faucet	C	4:00 PM	5	ND	Y	First Draw, Filtered.
Dicken-11	Room 109, Combination Sink, Faucet	C	3:15 PM	5	2	Y	First Draw, Filtered.
Dicken-12	Room 107, Combination Sink, Faucet	C	2:55 PM	5	4	Y	First Draw, Filtered.
Dicken-13	Room 122, Combination Sink, Bubbler	C	2:15 PM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Dicken Elementary School							
Date of Sampling: 12/14/2019							
Sampler: Steven Ripley							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Dicken-14	Room 120, Combination Sink, Bubbler	C	2:00 PM	5	ND	N	First Draw, Filtered.
Dicken-15	Room 118, Combination Sink, Bubbler	C	1:50 PM	5	ND	N	First Draw, Filtered.
Dicken-16	Room 116, Combination Sink, Bubbler	C	1:45 PM	5	ND	N	First Draw, Filtered.
Dicken-17	Room 119, Combination Sink, Bubbler	C	2:20 PM	5	ND	N	First Draw, Filtered.
Dicken-18	Room 117, Combination Sink, Bubbler	C	2:05 PM	5	ND	N	First Draw, Filtered.
Dicken-19	Room 102, Combination Sink, Bubbler	C	2:30 PM	5	ND	N	First Draw, Filtered.
Dicken-20	Room 104, Combination Sink, Bubbler	C	2:40 PM	5	ND	N	First Draw, Filtered.
Dicken-21	Room 106, Combination Sink, Bubbler	C	2:50 PM	5	ND	N	First Draw, Filtered.
Dicken-22	Room 108, Combination Sink, Bubbler	C	3:00 PM	5	ND	N	First Draw, Filtered.
Dicken-23	Room 110, Combination Sink, Bubbler	C	3:25 PM	5	ND	N	First Draw, Filtered.
Dicken-24	Room 112, Combination Sink, Bubbler	C	3:50 PM	5	ND	N	First Draw, Filtered.
Dicken-25	Room 114, Right Combination Sink, Faucet	C	4:15 PM	5	ND	Y	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/you-r-drinking-water/table-regulated-drinking-water-contaminant>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Dicken Elementary School							
Date of Sampling: 12/14/2019							
Sampler: Steven Ripley							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Dicken-26	Room 113, Right Combination Sink, Bubbler	C					Not Sampled, Not Currently in Service.
Dicken-27	Room 111, Combination Sink, Bubbler	C	3:40 PM	5	ND	N	First Draw, Filtered.
Dicken-28	Room 109, Combination Sink, Bubbler	C	3:15 PM	5	ND	N	First Draw, Filtered.
Dicken-29	Room 107, Combination Sink, Bubbler	C	2:55 PM	5	ND	N	First Draw, Filtered.
Dicken-30	Room 105, Combination Sink, Bubbler	C	2:45 PM	5	2	N	First Draw, Filtered.
Dicken-31	Room 103, Combination Sink, Bubbler	C	2:35 PM	5	ND	N	First Draw, Filtered.
Dicken-32	Hallway Outside Room 123, Hydration Station, Bottle Fill	BT	1:00 PM	5	ND	N	First Draw, Filtered.
Dicken-33	Hallway Outside Room 123, Hydration Station, Water Cooler	BT	1:00 PM	5	ND	Y	First Draw, Filtered.
Dicken-34	Room 128, Combination Sink, Bubbler	C	1:10 PM	5	ND	N	First Draw, Filtered.
Dicken-35	Room 126, Single Bubbler	B	1:15 PM	5	2	N	First Draw, Filtered.
Dicken-36	Gym, Single Bubbler	B	1:40 PM	5	ND	N	First Draw, Filtered.
Dicken-37	OPEN NUMBER						

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Dicken Elementary School							
Date of Sampling: 12/14/2019							
Sampler: Steven Ripley							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Dicken-38	Kitchen, 3-Compartment Sink, Add on Faucet, Far Right	KF	1:05 PM	5	ND	Y	First Draw, Filtered.
Dicken-39	Main Office, Kitchen Sink	KF	12:50 PM	5	ND	Y	First Draw, Filtered.
Dicken-40	Room 111, Combination Sink, Faucet	C	3:40 PM	5	ND	Y	First Draw, Filtered.
Dicken-41	Room 110, Combination Sink, Faucet	C	3:25 PM	5	4	Y	First Draw, Filtered.
Dicken-42	Room 108, Combination Sink, Faucet	C	3:00 PM	5	ND	Y	First Draw, Filtered.
Dicken-43	Room 106, Combination Sink, Faucet	C	2:50 PM	5	ND	Y	First Draw, Filtered.
Dicken-44	Room 105, Combination Sink, Faucet	C	2:45 PM	5	ND	Y	First Draw, Filtered.
Dicken-45	Room 103, Combination Sink, Faucet	C	2:35 PM	5	2	Y	First Draw, Filtered.
Dicken-46	Room 102, Combination Sink, Faucet	C	2:30 PM	5	2	Y	First Draw, Filtered.
Dicken-47	Room 117, Combination Sink, Faucet	C	2:05 PM	5	ND	Y	First Draw, Filtered.
Dicken-48	Room 119, Combination Sink, Faucet	C	2:20 PM	5	ND	Y	First Draw, Filtered.
Dicken-49	Room 122, Combination Sink, Faucet	C	2:15 PM	5	ND	Y	First Draw, Filtered.
Dicken-50	Room 120, Combination Sink, Faucet	C	2:00 PM	5	ND	Y	First Draw, Filtered.
Dicken-51	Room 118, Combination Sink, Faucet	C	1:50 PM	5	6	Y	First Draw, Filtered.
Dicken-52	Room 116, Combination Sink, Faucet	C	1:45 PM	5	4	Y	First Draw, Filtered.
Dicken-53	Room 128, Combination Sink, Faucet	C	1:10 PM	5	6	Y	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Dicken Elementary School							
Date of Sampling: 12/14/2019							
Sampler: Steven Ripley							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Dicken-54	Hallway, Outside Room 109, Hydration Station, Water Cooler	BT	3:30 PM	5	ND	N	First Draw, Filtered.
Dicken-55	Hallway, Outside Room 109, Hydration Station, Bottle Fill	BT	3:30 PM	5	ND	N	First Draw, Filtered.
Dicken-56	Hallway, Outside Gym, Hydration Station, Water Cooler	BT	2:25 PM	5	ND	N	First Draw, Filtered.
Dicken-57	Hallway, Outside Gym, Hydration Station, Bottle Fill	BT	2:25 PM	5	ND	N	First Draw, Filtered.
Dicken-58	Hallway, Outside Room 120, Hydration Station, Water Cooler	BT	1:55 PM	5	ND	N	First Draw, Filtered.
Dicken-59	Hallway, Outside Room 120, Hydration Station, Bottle Fill	BT	1:55 PM	5	ND	N	First Draw, Filtered.
Dicken-60	Exterior of Building, in Playground, Near Door 6, Bubbler	B					Location Turned off for Winter, to be Sampled at a Later Date.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030

Dicken Elementary School							
Date of Sampling: 1/3/2020							
Sampler: Alex Reiber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Dicken-26	Room 113, Right Combination Sink, Bubbler	C	12:20 PM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested



Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030

Dicken Elementary School							
Date of Sampling: 12/24/2019							
Sampler: Carly Doulos							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Dicken-05A	Room 114, Left Combination Sink, Faucet	C	8:45 AM	5	ND ³	Y	Repeat First Draw, Filtered. Elevated Lead Attributed to Sediement in Aerator. Aerator Placed on Cleaning Schedule.
Dicken-51A	Room 118, Combination Sink Faucet	C	8:51 AM	5	ND	Y	Repeat First Draw, Filtered. Elevated Lead Attributed to Sediement in Aerator. Aerator Placed on Cleaning Schedule.
Dicken-53A	Room 128, Combination Sink Faucet	C	8:39 AM	5	ND	Y	Repeat First Draw, Filtered. Elevated Lead Attributed to Sediement in Aerator. Aerator Placed on Cleaning Schedule.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested