



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE230030

Mitchell Elementary School

Date of Sampling: January 5, 2023

Sampler: Sabrina Fouche

Sample #	Location	Type ¹	Time Collected	District Lead Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Mitchell-04	Room 4, Combination Sink, Glass Filler	C	9:18 AM	5	ND ³	N	Y	6/20/22	Initial First Draw, Filtered.
Mitchell-08	Teacher's Lounge, Combination Sink, Glass Filler	C	9:39 AM	5	ND	N	Y	6/20/22	Initial First Draw, Filtered.
Mitchell-12	Hallway, Across from Room 23, Hydration Station, Bottle Fill	HS	9:57 AM	5	ND	Y	Y	Green	Initial First Draw, Filtered.
Mitchell-17	Hallway, Outside Gym, Hydration Station, Bottle Fill	HS	10:00 AM	5	ND	Y	Y	Unknown	Initial First Draw, Filtered.
Mitchell-20	Room 2, Combination Sink, Right Sink, Glass Filler	C	9:15 AM	5	ND	N	Y	6/20/22	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE230030

Mitchell Elementary School									
Date of Sampling: January 5, 2023									
Sampler: Sabrina Fouche									
Sample #	Location	Type ¹	Time Collected	District Lead Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Mitchell-35	Room 6, Combination Sink, Middle Sink, Glass Filler	C	9:12 AM	5	ND	N	Y	6/20/22	Initial First Draw, Filtered.
Mitchell-38	Room 9, Combination Sink, Left Sink, Glass Filler	C	9:30 AM	5	ND	N	Y	6/21/22	Initial First Draw, Filtered.
Mitchell-55	Room 19, Combination Sink, Glass Filler	C	9:47 AM	5	ND	N	Y	No date	Initial First Draw, Filtered.
Mitchell-47	Room 15, Combination Sink, Glass Filler	C	9:36 AM	5	ND	N	Y	6/21/22	Initial First Draw, Filtered.
Mitchell-57	Kitchen, 3-Compartment Sink, Far Left, Faucet	F	9:42 AM	5	ND	Y	Y	6/20/22	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE230030

Mitchell Elementary School									
Date of Sampling: January 5, 2023									
Sampler: Sabrina Fouche									
Sample #	Location	Type ¹	Time Collected	District Lead Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Mitchell-63	Room 25, Combination Sink, Glass Filler	C	9:25 AM	5	ND	N	Y	6/20/22	Initial First Draw, Filtered.
Mitchell-73	Room 21, Combination Sink, Glass Filler	C	9:22 AM	5	ND	N	Y	6/20/22	Initial First Draw, Filtered.
Mitchell-82	Art Room, Right Most Sink, Combination Sink, Glass Filler	C	9:33 AM	5	ND	N	Y	6/21/22	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L