



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE240030

Site: Westerman Preschool												
Sampling Type: Initial First Draw Sampling (IFD)												
Date of Sampling: February 16, 2024												
Sampler: Dean Johnson												
Sample #	Location	Fixture Type	Time Collected	District Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date	Notes	Flushing Dates	Corrective Actions	Location Completed
PFC-01	Hallway Outside Room B112, Refrigerated Glass Filler	Water Cooler	5:02pm	5	ND	Y	N/A	N/A				
PFC-02	Room A102, Combination Sink, Glass Filler	Combination Sink	4:50pm	5	ND	Y	N/A	N/A				
PFC-03	Room A100, Combination Sink, Glass Filler	Combination Sink	4:50pm	5	ND	Y	N/A	N/A				
PFC-04	Room B102, Combination Sink, Glass Filler	Combination Sink	5:10pm	5	ND	Y	N/A	N/A				
PFC-05	Room B105, Combination Sink, Glass Filler	Combination Sink	5:28pm	5	ND	Y	N/A	N/A				
PFC-06	Lobby, Outside Room E100, Combination Sink, Glass Filler	Combination Sink	5:42pm	5	ND	Y	Y	7/18/2023				
PFC-07	Room A108, Combination Sink, Glass Filler	Combination Sink	4:57pm	5	ND	Y	N/A	N/A				
PFC-10	Room D100, Combination Sink, Glass Filler	Combination Sink	6:37pm	5	ND	Y	N/A	N/A				
PFC-12	Room D102, Combination Sink, Glass Filler	Combination Sink	6:37pm	5	ND	Y	N/A	N/A				
PFC-13	Kitchen, 3-Compartment Sink, Middle Faucet	Kitchen Faucet	5:54pm	5	ND	Y	N	N/A				
PFC-15	Hallway Outside Room D109, Hydration Station, Bottle Fill	Hydration Station	6:17pm	5	ND	Y	Y	N/A				
PFC-17	Room C105, Combination Sink, Glass Filler	Combination Sink	6:02pm	5	ND	Y	N/A	N/A				
PFC-21	Room C103, Combination Sink, Glass Filler	Combination Sink	6:02pm	5	ND	Y	N/A	N/A				
PFC-23	Room C102, Combination Sink, Glass Filler	Combination Sink	6:11pm	5	ND	Y	N/A	N/A				

*ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE240030

Site: Westerman Preschool												
Sampling Type: Initial First Draw Sampling (IFD)												
Date of Sampling: February 16, 2024												
Sampler: Dean Johnson												
Sample #	Location	Fixture Type	Time Collected	District Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date	Notes	Flushing Dates	Corrective Actions	Location Completed
PFC-25	Room C100, Combination Sink, Glass Filler	Combination Sink	6:11pm	5	ND	Y	N/A	N/A				
PFC-27	Room C112, Combination Sink, Glass Filler	Combination Sink	6:24pm	5	ND	Y	N/A	N/A				
PFC-31	Room D104, Combination Sink, Glass Filler	Combination Sink	6:47pm	5	ND	Y	N/A	N/A				
PFC-34	Room D103, Combination Sink, Glass Filler	Combination Sink	6:47pm	5	ND	Y	N/A	N/A				
PFC-39	Room E105, Combination Sink, Glass Filler	Combination Sink	5:48pm	5	ND	Y	Y	7/20/2023				
PFC-43	Room B100, Combination Sink, Glass Filler	Combination Sink	5:10pm	5	ND	Y	N/A	N/A				
PFC-48	Room B103, Combination Sink, Glass Filler	Combination Sink	5:28pm	5	ND	Y	N/A	N/A				
PFC-53	Room A105, Combination Sink, Glass Filler	Combination Sink	4:38pm	5	ND	Y	N/A	N/A				
PFC-57	Room A103, Combination Sink, Glass Filler	Combination Sink	4:39pm	5	ND	Y	N/A	N/A				
PFC-65	Hallway Outside Room B112, Hydration Station, Bottle Fill	Hydration Station	5:02pm	5	ND	Y	Y	N/A				
PFC-68	Room E100, Hydration Station, Bottle Fill	Hydration Station	5:42pm	5	ND	Y	Y	Green				
PFC-76	Classroom C105 and C103 Bathroom, Left Faucet	Bathroom Faucet	6:02pm	5	ND	Y	Y	7/20/2023				
PFC-79	Classroom C102 and C100 Bathroom, Left Faucet	Bathroom Faucet	6:11pm	5	ND	Y	Y	7/20/2023				
PFC-81	Classroom C102 and C100 Bathroom, Right Faucet	Bathroom Faucet	6:11pm	5	ND	Y	Y	7/20/2023				

*ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE240030

Site: Westerman Preschool												
Sampling Type: Initial First Draw Sampling (IFD)												
Date of Sampling: February 16, 2024												
Sampler: Dean Johnson												
Sample #	Location	Fixture Type	Time Collected	District Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date	Notes	Flushing Dates	Corrective Actions	Location Completed
PFC-82	Classroom D100 and D102 Bathroom, Left Faucet	Bathroom Faucet	6:37pm	5	ND	Y	Y	7/19/2023				
PFC-83	Classroom D100 and D102 Bathroom, Middle Faucet	Bathroom Faucet	6:37pm	5	ND	Y	Y	7/19/2023				
PFC-84	Classroom D100 and D102 Bathroom, Right Faucet	Bathroom Faucet	6:37pm	5	ND	Y	Y	7/19/2023				
PFC-85	Classroom D104 and D103 Bathroom, Left Faucet	Bathroom Faucet	6:47pm	5	6	Y	Y	7/19/2023		AEG returned on 07/29/24 to flush the fixtures identified above lead action level. However, the fixture was removed.	Fixture Removed	Yes
PFC-86	Classroom D104 and D103 Bathroom, Middle Faucet	Bathroom Faucet	6:47pm	5	5	Y	Y	7/19/2023		AEG returned on 07/29/24 to flush the fixtures identified above lead action level. However, the fixture was removed.	Fixture Removed	Yes
PFC-87	Classroom D104 and D103 Bathroom, Right faucet	Bathroom Faucet	6:47pm	5	19	Y	Y	7/19/2023		AEG returned on 07/29/24 to flush the fixtures identified above lead action level. However, the fixture was removed.	Fixture Removed	Yes
PFC-88	Classroom D107 Bathroom, Left Faucet	Bathroom Faucet	6:30pm	5	ND	Y	Y	7/19/2023				
PFC-89	Classroom D107 Bathroom, Right Faucet	Bathroom Faucet	6:30pm	5	43	Y	Y	7/19/2023		AEG returned on 07/29/24 to flush the fixtures identified above lead action level. However, the fixture was removed.	Fixture Removed	Yes
PFC-93	Clinic Room E102 Bathroom, Left Faucet	Bathroom Faucet	6:30pm	5	ND	Y	Y	7/18/2023				
PFC-95	Classroom A100 and A102 Bathroom, Left Faucet	Bathroom Faucet	4:55pm	5	ND	Y	Y	7/17/2023				
PFC-96	Classroom A100 and A102 Bathroom, Middle Faucet	Bathroom Faucet	4:53pm	5	ND	Y	Y	7/17/2023				
PFC-97	Classroom A100 and A102 Bathroom, Right Faucet	Bathroom Faucet	4:53pm	5	ND	Y	Y	7/17/2023				
PFC-98	Classroom A103 and A105 Bathroom, Left Faucet	Bathroom Faucet	4:41pm	5	ND	Y	Y	7/20/2023				
PFC-99	Classroom A103 and A105 Bathroom, Middle Faucet	Bathroom Faucet	4:41pm	5	ND	Y	Y	7/20/2023				

*ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE240030

Site: Westerman Preschool												
Sampling Type: Initial First Draw Sampling (IFD)												
Date of Sampling: February 16, 2024												
Sampler: Dean Johnson												
Sample #	Location	Fixture Type	Time Collected	District Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date	Notes	Flushing Dates	Corrective Actions	Location Completed
PFC-100	Classroom A103 and A105 Bathroom, Right Faucet	Bathroom Faucet	4:41pm	5	ND	Y	Y	7/20/2023				
PFC-108	Classroom B100 and B102 Bathroom, Left Faucet	Bathroom Faucet	5:13pm	5	ND	Y	Y	7/17/2023				
PFC-110	Classroom B100 and B102 Bathroom, Right Faucet	Bathroom Faucet	5:13pm	5	ND	Y	Y	7/17/2023				
PFC-111	Classroom B105 and B103 Bathroom, Left Faucet	Bathroom Faucet	5:30pm	5	ND	Y	Y	7/17/2023				
PFC-112	Classroom B105 and B103 Bathroom, Middle Faucet	Bathroom Faucet	5:30pm	5	ND	Y	Y	7/17/2023				
PFC-113	Classroom B105 and B103 Bathroom, Right Faucet	Bathroom Faucet	5:30pm	5	ND	Y	Y	7/17/2023				

*ND = Non-Detected at Reported Detection Limit of 1 ug/L