



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

<b>Pittsfield Elementary School</b>							
<b>Date of Sampling: 1/18/2020</b>							
<b>Sampler: Alex Reiber</b>							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pittsfield-01	Hallway Across from Boiler Room, Hydration Station, Water Cooler	BT	2:45 PM	5	ND <sup>3</sup>	N	First Draw, Filtered.
Pittsfield-02	Staff Lounge, Kitchen Faucet	KF	2:35 PM	5	ND	Y	First Draw, Filtered.
Pittsfield-03	Hallway Across from Boiler Room, Hydration Station, Bottle Fill	BT	2:45 PM	5	ND	Y	First Draw, Filtered.
Pittsfield-04	Hallway Outside Room 106, Hydration Station, Water Cooler	BT	3:20 PM	5	ND	N	First Draw, Filtered.
Pittsfield-05	Hallway Outside Gym, Hydration Station, Water Cooler	BT	4:30 PM	5	ND	N	First Draw, Filtered.
Pittsfield-06	Room 115, Combination Sink, Bubbler	C	2:20 PM	5	ND	N	First Draw, Filtered.
Pittsfield-07	Room 101, Combination Sink, Bubbler	C	2:50 PM	5	ND	Y	First Draw, Filtered.
Pittsfield-08	Room 103, Combination Sink, Bubbler	C	3:15 PM	5	ND	N	First Draw, Filtered.
Pittsfield-09	Room 106, Combination Sink, Bubbler	C	3:45 PM	5	2	N	First Draw, Filtered.
Pittsfield-10	Room 107, Combination Sink, Bubbler	C	3:50 PM	5	1	N	First Draw, Filtered.
Pittsfield-11	Room 108, Combination Sink, Bubbler	C	3:55 PM	5	ND	N	First Draw, Filtered.
Pittsfield-12	Room 109, Combination Sink, Bubbler	C	2:40 PM	5	ND	N	First Draw, Filtered.
Pittsfield-13	Hallway Outside Gym, Hydration Station, Bottle Fill	BT	4:30 PM	5	ND	Y	First Draw, Filtered.
Pittsfield-14	Room 115, Combination Sink, Faucet	C	2:20 PM	5	1	Y	First Draw, Filtered.
Pittsfield-15	Room 101, Combination Sink, Faucet	C	2:50 PM	5	ND	Y	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

<b>Pittsfield Elementary School</b>							
<b>Date of Sampling: 1/18/2020</b>							
<b>Sampler: Alex Reiber</b>							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pittsfield-16	Room 103, Combination Sink, Faucet	C	3:15 PM	5	2	N	First Draw, Filtered.
Pittsfield-17	Room 106, Combination Sink, Faucet	C	3:45 PM	5	2	Y	First Draw, Filtered.
Pittsfield-18	Room 107, Combination Sink, Faucet	C	3:50 PM	5	ND	N	First Draw, Filtered.
Pittsfield-19	Room 108, Combination Sink, Faucet	C	3:55 PM	5	2	Y	First Draw, Filtered.
Pittsfield-20	Room 109, Combination Sink, Faucet	C	2:40 PM	5	ND	Y	First Draw, Filtered.
Pittsfield-21	Room 105, Combination Sink, Bubbler	C	3:35 PM	5	ND	N	First Draw, Filtered.
Pittsfield-22	Room 105, Combination Sink, Faucet	C	3:35 PM	5	2	Y	First Draw, Filtered.
Pittsfield-23	Room 104, Combination Sink, Bubbler	C	3:30 PM	5	ND	N	First Draw, Filtered.
Pittsfield-24	Room 104, Combination Sink, Faucet	C	3:30 PM	5	ND	Y	First Draw, Filtered.
Pittsfield-25	Room 102, Combination Sink, Bubbler	C	2:55 PM	5	ND	N	First Draw, Filtered.
Pittsfield-26	Room 102, Combination Sink, Faucet	C	2:55 PM	5	4	Y	First Draw, Filtered.
Pittsfield-27	Room 116, Combination Sink, Bubbler	C	2:10 PM	5	ND	N	First Draw, Filtered.
Pittsfield-28	Room 116, Combination Sink, Faucet	C	2:10 PM	5	ND	Y	First Draw, Filtered.
Pittsfield-29	Room 114, Combination Sink, Bubbler	C	2:25 PM	5	ND	N	First Draw, Filtered.
Pittsfield-30	Room 114, Combination Sink, Faucet	C	2:25 PM	5	3	Y	First Draw, Filtered.
Pittsfield-31	Room 112, Combination Sink, Bubbler	C	4:15 PM	5	ND	N	First Draw, Filtered.
Pittsfield-32	Room 112, Combination Sink, Faucet	C	4:15 PM	5	ND	Y	First Draw, Filtered.
Pittsfield-33	Room 111, Combination Sink, Bubbler	C	4:20 PM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

Pittsfield Elementary School							
Date of Sampling: 1/18/2020							
Sampler: Alex Reiber							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pittsfield-34	Room 111, Combination Sink, Faucet	C	4:20 PM	5	1	Y	First Draw, Filtered.
Pittsfield-35	Music Room, Combination Sink, Bubbler	C	4:35 PM	5	ND	N	First Draw, Filtered.
Pittsfield-36	Music Room, Combination Sink, Faucet	C	4:35 PM	5	ND	N	First Draw, Filtered.
Pittsfield-37	Kitchen, 3-Compartment Sink, Add On Far Right Faucet	KF	4:50 PM	5	ND	Y	First Draw, Filtered.
Pittsfield-38	Hallway Outside Room 106, Hydration Station, Water Cooler	BT	3:20 PM	5	ND	Y	First Draw, Filtered.
Pittsfield-39	Media Center, Single Sink, Faucet	F	4:05 PM	5	3	Y	First Draw, Filtered.
Pittsfield-40	Hallway, Outside Room 112, Hydration Station, Water Cooler	BT	4:00 PM	5	ND	N	First Draw, Filtered.
Pittsfield-41	Hallway, Outside Room 112, Hydration Station, Bottle Fill	BT	4:00 PM	5	ND	Y	First Draw, Filtered.
Pittsfield-42	Clinic, Off of Main Office, Faucet	F	4:55 PM	5	ND	Y	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested

Action Level >5ppb