



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

Community High School							
Date of Sampling: 2/22/2020							
Sampler: Lindsey Eveleth							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Community-01	Main Office, Second Floor, In Closet, Staff Single Sink	F	11:32 AM	5	ND <sup>3</sup>	Y	First Draw, Filtered.
Community-02	Hallway, Outside Room 212, Hydration Station, Water Cooler	BT	11:15 AM	5	ND	N	First Draw, Filtered.
Community-03	Hallway, Outside Room 310, Hydration Station, Water Cooler	BT	11:45 AM	5	ND	N	First Draw, Filtered.
Community-04	Hallway, Outside Room 310, Hydration Station, Bottle Fill	BT	11:46 AM	5	ND	N	First Draw, Filtered.
Community-05	Hallway, Outside Room 306, Single Water Cooler	WC	11:42 AM	5	ND	N	First Draw, Filtered.
Community-06	Hallway, Outside Room 303, Hydration Station, Water Cooler	BT	11:35 AM	5	ND	N	First Draw, Filtered.
Community-07	Hallway, Outside Room 315, Hydration Station, Water Cooler	BT	11:40 AM	5	ND	N	First Draw, Filtered.
Community-08	Hallway, Outside Room 213, Hydration Station, Water Cooler	BT	11:22 AM	5	ND	N	First Draw, Filtered.
Community-09	Clinic, Second Floor, Single Sink	F	11:28 AM	5	ND	Y	First Draw, Filtered.
Community-10	Hallway, Outside Room 303, Hydration Station, Bottle Fill	BT	11:37 AM	5	ND	N	First Draw, Filtered.
Community-11	Hallway, Outside Room 118, Hydration Station, Water Cooler	BT	11:05 AM	5	ND	N	First Draw, Filtered.
Community-12	Hallway, Across from Room 111, Hydration Station, Water Cooler	BT	11:00 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

Community High School							
Date of Sampling: 2/22/2020							
Sampler: Lindsey Eveleth							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Community-13	Media Center, Single Sink	F	11:20 AM	5	2	Y	First Draw, Filtered.
Community-14	Hallway, Outside Room 118, Hydration Station, Bottle Fill	BT	11:07 AM	5	ND	N	First Draw, Filtered.
Community-15	Hallway, Outside Room 212, Hydration Station, Bottle Fill	BT	11:17 AM	5	ND	N	First Draw, Filtered.
Community-16	Hallway, Outside Room 213, Hydration Station, Bottle Fill	BT	11:23 AM	5	ND	N	First Draw, Filtered.
Community-17	Hallway, Across from Room 111, Hydration Station, Bottle Fill	BT	11:03 AM	5	ND	N	First Draw, Filtered.
Community-18	Hallway, Outside Room 315, Hydration Station, Bottle Fill	BT	11:41 AM	5	ND	N	First Draw, Filtered.
Community-19	OPEN NUMBER			5			
Community-20	Kitchen, Single Prep Sink	KF	11:09 AM	5	ND	Y	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested