



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE240030

Site: Forsythe Middle School									
Sampling Type: Initial First Draw Sampling (IFD)									
Date of Sampling: February 10, 2024									
Sampler: Maryn Burrell									
Sample #	Location	Fixture Type	Time Collected	District Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date	Notes
Forsythe-10	Kitchen, 3-Comp Sink, Add On Faucet, Far Right, Glass Filler	Kitchen Faucet	12:30 PM	5	1	Y	Y	8/31/2023	
Forsythe-18	Hallway, Outside Room 401, Refridgerated Glass Filler	Water Cooler	1:00 PM	5	ND	Y	N/A	N/A	
Forsythe-31	Gymnasium, Outside Boys Locker Room, Porcelain, Glass Filler	Single Bottle Fill	12:45 PM	5	ND	Y	N	N/A	
Forsythe-39	Hallway, Outside Room 113, Hydration Station, Bottle Fill	Hydration Station	12:40 PM	5	ND	Y	N	N/A	
Forsythe-02	Extra location in kitchen	Faucet	12:35 PM	5	3	Y	Y	N/A	
Forsythe-33	Boys locker room	Hydration Station	12:50 PM	5	1	Y	Y	N/A	

*ND = Non-Detected at Reported Detection Limit of 1 ug/L