



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Clague Middle School							
Date of Sampling: 11/27/2019							
Sampler: Steven Ripley							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Clague-01	Main Entrance/Lobby, Single Water Cooler	WC	9:15 AM	5	ND ³	N	First Draw, Filtered.
Clague-02	Hallway, Outside Room 146, Left of Elevator, Hydration Station, Water Cooler	BT	11:00 AM	5	ND	N	First Draw, Filtered.
Clague-03	Cafeteria, Hydration Station, Water Cooler	BT	10:09 AM	5	ND	N	First Draw, Filtered.
Clague-04	OPEN NUMBER						
Clague-05	OPEN NUMBER						
Clague-06	Hallway Outside Pool, Single Water Cooler	WC	10:14 AM	5	ND	N	First Draw, Filtered.
Clague-07	Hallway, to the Left of Laundry Room by Gym, Hydration Station, Water Cooler	BT	10:46 AM	5	ND	N	First Draw, Filtered.
Clague-08	Hallway, Outside Room 229 and Elevator, Hydration Station, Water Cooler	BT	1:25 PM	5	ND	N	First Draw, Filtered.
Clague-09	OPEN NUMBER						
Clague-10	Room 226, Faucet	F	2:30 PM	5	2	Y	First Draw, Filtered.
Clague-11	Hallway, Outside Room 223, Hydration Station, Water Cooler	BT	2:12 PM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Clague Middle School							
Date of Sampling: 11/27/2019							
Sampler: Steven Ripley							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Clague-12	Hallway, Outside Room 146, Left of Elevator, Hydration Station, Bottle Fill	BT	11:00 AM	5	ND	N	First Draw, Filtered.
Clague-13	Hallway, Outside Room 229 and Elevator, Hydration Station, Bottle Fill	BT	1:25 PM	5	ND	N	First Draw, Filtered.
Clague-14	Hallway, Outside Room 223, Hydration Station, Bottle Fill	BT	2:12 PM	5	ND	N	First Draw, Filtered.
Clague-15	Room 223, Music Room Faucet	F	2:15 PM	5	1	Y	First Draw, Filtered.
Clague-16	Hallway, Outside Room 216, Hydration Station, Bottle Fill	BT	2:10 PM	5	ND	N	First Draw, Filtered.
Clague-17	Dressing Room, Right Faucet	F	2:24 PM	5	17	Y	First Draw, Filtered.
Clague-18	Dressing Room, Left Faucet	F	2:24 PM	5	5	Y	First Draw, Filtered.
Clague-19	Room 228, Left Single Sink Faucet	F	1:40 PM	5	7	Y	First Draw, Filtered.
Clague-20	Room 229, Faucet	F	1:35 PM	5	ND	Y	First Draw, Filtered.
Clague-21	Room 230, Right Single Sink Faucet	F	1:28 PM	5	9	Y	First Draw, Filtered.
Clague-22	Room 230, Left Single Sink Faucet	F	1:28 PM	5	ND	Y	First Draw, Filtered.
Clague-23	Hallway, Outside Room 204, Hydration Station, Water Cooler	BT	1:50 PM	5	ND	N	First Draw, Filtered.
Clague-24	Second Floor Teacher's Lounge, Faucet	F	2:00 PM	5	ND	Y	First Draw, Filtered.
Clague-25	Hallway Outside Room 208, Water Cooler	WC	1:56 PM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Clague Middle School							
Date of Sampling: 11/27/2019							
Sampler: Steven Ripley							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Clague-26	Room 208, Faucet	F	2:05 PM	5	ND	Y	First Draw, Filtered.
Clague-27	Hallway Outside Room 216, Hydration Station, Water Cooler	BT	2:10 PM	5	ND	N	First Draw, Filtered.
Clague-28	Hallway, to the Left of Laundry Room by Gym, Hydration Station, Bottle Fill	BT		5			Not Sampled Due to Broken Bottle Fill Sensor
Clague-29	Gym, South Corner, Bubbler	B	10:39 AM	5	ND	N	First Draw, Filtered.
Clague-30	Gym, North Corner, Water Cooler	WC	10:39 AM	5	ND	N	First Draw, Filtered.
Clague-31	Room 146, Conference Room Faucet	F	11:38 AM	5	1	Y	First Draw, Filtered.
Clague-32	Cafeteria, Hydration Station, Bottle Fill	BT	10:09 AM	5	ND	N	First Draw, Filtered.
Clague-33	OPEN			5			
Clague-34	Girl's Locker Room, Water Cooler	WC	10:30 AM	5	ND	N	First Draw, Filtered.
Clague-35	Boy's Locker Room, Water Cooler	WC	10:35 AM	5	ND	N	First Draw, Filtered.
Clague-36	Room 143, Faucet	F	11:30 AM	5	5	Y	First Draw, Filtered.
Clague-37	Kitchen, Singular Central Sink, Faucet	F	10:55 AM	5	ND	Y	First Draw, Filtered.
Clague-38	Hallway, Outside Room 144, Single Water Cooler	WC	11:34 AM	5	ND	N	First Draw, Filtered.
Clague-39	Pool, South wall, Right Bubbler	B	10:20 AM	5	ND	N	First Draw, Filtered.
Clague-40	Pool, South Wall, Left Bubbler	B	10:20 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Clague Middle School							
Date of Sampling: 11/27/2019							
Sampler: Steven Ripley							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Clague-41	Hallway, Outside Room 131, Hydration Station, Bottle Fill	BT	9:58 AM	5	ND	N	First Draw, Filtered.
Clague-42	"Blue House" Room, West of Room 136, Faucet	F	10:05 AM	5	ND	Y	First Draw, Filtered.
Clague-43	Hallway, Outside Room 131, Hydration Station, Water Cooler	WC	9:58 AM	5	ND	N	First Draw, Filtered.
Clague-44	Hallway, Outside Room 204, Hydration Station, Bottle Fill	BT	1:50 PM	5	ND	N	First Draw, Filtered.
Clague-45	Hallway, Outside Room 124, Water Cooler	WC	4:43 PM	5	ND	N	First Draw, Filtered.
Clague-46	Media Center Work Room, Faucet	F	4:54 PM	5	2	Y	First Draw, Filtered.
Clague-47	Hallway, Outside Main Offices, Hydration Station, Water Cooler	WC	9:36 AM	5	ND	N	First Draw, Filtered.
Clague-48	Clinic, Faucet	F	9:26 AM	5	2	Y	First Draw, Filtered.
Clague-49	Room 141, First End Sink Closest to the Entry Door	F	11:07 AM	5	3	N	First Draw, Filtered.
Clague-50	Room 141, Second Middle Sink Closest to the Entry Door	F	11:08 AM	5	2	N	First Draw, Filtered.
Clague-51	Room 141, Third Middle Sink Farthest From the Entry Door	F	11:09 AM	5	ND	N	First Draw, Filtered.
Clague-52	Room 141, Fourth End Sink Farthest from the Entry Door	F	11:10 AM	5	13	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Clague Middle School							
Date of Sampling: 11/27/2019							
Sampler: Steven Ripley							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Clague-53	Room 142, First Sink Closest to the Entry Door	F	11:16 AM	5	ND	Y	First Draw, Filtered.
Clague-54	Room 142, Second Sink From the Entry Door	F	11:17 AM	5	ND	N	First Draw, Filtered.
Clague-55	Room 142, Third Sink From the Entry Door	F	11:18 AM	5	ND	N	First Draw, Filtered.
Clague-56	Room 142, Fourth Sink From the Entry Door	F	11:20 AM	5	ND	N	First Draw, Filtered.
Clague-57	Room 142, Fifth Sink From the Entry Door	F	11:21 AM	5	ND	N	First Draw, Filtered.
Clague-58	OPEN NUMBER			5			
Clague-59	Hallway, Outside Main Offices, Hydration Station, Bottle Fill	BT	9:36 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030

Clague Middle School							
Date of Sampling: 11/27/2019							
Sampler: Steven Ripley							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Clague-28	Hallway, to the Left of Laundry Room by Gym, Hydration Station, Bottle Fill	BT	8:45 AM	5	ND	N	First Draw, Filtered. Bottle Fill Sensor Repaired.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Clague Middle School							
Date of Sampling: N/A							
Sampler: N/A							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Clague-17	Dressing Room, Right Faucet	F	N/A	5	N/A	Y	Identified as an Area of Infrequent Use, Designated as a Non-Potable Water Source.
Clague-19	Room 228, Single Sink Faucet	F	N/A	5	N/A	Y	Identified as an Area of Infrequent Use, Designated as a Non-Potable Water Source.
Clague-21	Room 230, Right Single Sink, Faucet	F	N/A	5	N/A	Y	Identified as an Area of Infrequent Use, Designated as a Non-Potable Water Source.
Clague-52	Room 141, Fourth End Sink Farthest from the Entry Door	F	N/A	5	N/A	N	Identified as an Area of Infrequent Use, Designated as a Non-Potable Water Source.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested