



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE230030

Forsythe Middle School

Date of Sampling: January 3, 2023

Sampler: Victoria Heed

Sample #	Location	Type ¹	Time Collected	District Lead Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Forsythe-01	Room 112, Wood Shop, Combination Sink, Bottle Fill	C	11:06 AM	5	ND ³	N	Y	8/12/2022	Initial First Draw, Filtered.
Forsythe-04	Room 113, Stainless Glass Filler	G	11:00 AM	5	ND	N	Y	8/12/2022	Initial First Draw, Filtered.
Forsythe-13	Cafeteria, Double Glass Filler, Left Glass Filler	G	10:41 AM	5	ND	N	Y	Filter Behind Wall	Initial First Draw, Filtered.
Forsythe-38	Hallway, Outside From Room 501, Hydration Station, Bottle Fill	HS	10:45 AM	5	ND	Y	Y	Green	Initial First Draw, Filtered.
Forsythe-30	Gymnasium, Outside Girls Locker Room, Wall Glass Filler	G	10:54 AM	5	ND	N	Y	Filter Behind Wall	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE230030

Forsythe Middle School									
Date of Sampling: January 3, 2023									
Sampler: Victoria Heed									
Sample #	Location	Type ¹	Time Collected	District Lead Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Forsythe-36	Hallway, Outside From Room 614, Refrigerated Glass Filler	G	10:49 AM	5	ND	N	Y	Unknown Filter Date	Initial First Draw, Filtered.
Forsythe-41	Auditorium Lobby, Hydration Station, Bottle Fill	HS	11:10 AM	5	ND	Y	Y	Green	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L